Town of Cobourg
Barrier Free Bathroom Renovation
REQUEST FOR QUOTATION NO: CO-17-04

ADDENDUM NO. 2 – March 21ST, 2017

This addendum forms part of the Contract and amends the documents. To confirm receipt of this addendum, please fill in the information below and email the cover page to Julie Behan-Jones at jbehanjones@cobourg.ca

The cover page of this Addendum must also be returned with the completed Form of Quotation or the Tender submitted may be rejected.

This Addendum shall take precedence over all requirements of the contract documents issued previously.

The undersigned hereby confirms receipt of Addendum #1 issued March 21ST, 2017	
Name (Print):	**Company:**
Signature:	**Date:**

The deadline for questions on the RFQ Documents is Tuesday March 21st, 2017, 5:00 pm.

ADDENDUM:

SUBMITTED – QUESTIONS:

QUESTION	RESPONSE
1. Are new floor drains required on this project?	The existing floor drain can remain in place. The dividing wall to be constructed over top the existing floor drain to be stepped approximately one inch above the floor drain to permit drainage from either washroom
2. What size exhaust fans are required?	Contractors are to size according to Ontario Building Code regulations.
3. Are the existing walls & ceiling to be painted?	Yes
4. Is the existing floor drain large enough and deep enough for hooking into?	Existing floor drain depth is unknown. It is recommended that contractors perform due diligence with respect the depth of the existing floor drain depth.
5. Do we need to include a stud wall to hide new plumbing?	Yes
6. Is garburator in existing fish cleaning station being reused outside?	No

All questions about the Tender documents and Drawings should be directed to Paul Gauthier (pgauthier@cobourg.ca), Manager, Waterfront Facilities, Town of Cobourg.

Only questions received in writing via email will be considered official for inclusion in future Addenda.

END OF ADDENDUM

NO. OF PAGES INCLUDED: 2
NO. OF DRAWINGS INCLUDED: 0
NO.OF SKETCHES INCLUDED: 0
NO. OF SPECIFICATION SECTIONS INCLUDED: 0
NO. OF TABLE PAGES INCLUDED: 0