


2025

Annual
Summary
Report

The Corporation of the Town of Cobourg

Cobourg Drinking Water System



CONTENTS

1.	PURPOSE	3
2.	COBOURG DRINKING WATER SYSTEM OVERVIEW	4
3.	2025 COMPLIANCE.....	4
	3.1 MECP Inspection	4
	3.2 License & Permit Compliance	4
	3.3 Adverse Water Quality Incident(s).....	7
4.	CONTINUAL IMPROVEMENT	8
5.	SAMPLING AND ANALYSIS	9

1. PURPOSE

The purpose of the Annual Summary Report is to provide information to residents and stakeholders of the Town of Cobourg. Furthermore, satisfying the regulatory requirements of the *Safe Drinking Water Act, 2002* including the Drinking Water Quality Management Standard (DWQMS) reports to owner, and regulatory reporting required under *Ontario Regulation 170/03*. This annual summary report fulfills all requirements of *Ontario Regulation 170/03* Section 11 Annual Reports and Schedule 22 Summary Reports for Municipalities.

The Annual Summary Report is prepared by Lakefront Utility Services Inc. (operating authority) on behalf of The Town of Cobourg (owner).

Scope

The Annual Summary Report includes information pertaining to the Town of Cobourg's Drinking Water System (DWS) for the period of January 1, 2025 to December 31, 2025. *Ontario Regulation 170/03* requires reported information be provided to:

- **Drinking Water System Owners (Mayor and Council)**
- **Owner and Operating Authority Top Management**
- **The Public**

Availability

The Cobourg DWS is a large municipal residential system that serves more than 10,000 people. Copies of this annual summary report are available online at <https://www.lakefrontutilities.com/regulatory-water/>. Hard copies are also available at the LUSI's office at 207 Division St, Cobourg ON, K9A 4L3.

Customers of the Cobourg DWS are notified that the annual summary report is available via "What's New" <https://www.lakefrontutilities.com/whats-new/>, social media posts and "Stay Connected" LUSI bill insert.

Council Resolution

Ontario Regulation 170/03 requires Summary Reports be distributed to municipal council no later than March 31 of each year. The Town of Cobourg must provide LUSI with a copy of council resolution indicating the report has been accepted.

2. COBOURG DRINKING WATER SYSTEM OVERVIEW

The Cobourg Water Treatment Plant (WTP) takes water from Lake Ontario through an 860m-long intake pipe. Raw water is pre-chlorinated for zebra-mussel control before it enters a full conventional treatment process. The treatment process includes coagulation, flocculation, sedimentation, and filtration. *Aluminum sulphate* is used as the coagulation agent, with an addition of *Flowpam AN 934 PWG* (polymer) to aid in the process. Primary disinfection is achieved with *gaseous chlorine* after which the water is stored in a 6,240 m³ in-ground reservoir, from where it is pumped to the distribution system.

The distribution system consists of two pressure zones, with an elevated water storage tank in each of the zones. The WTP supplies water to the D'Arcy St. tower (new in 2025), with a holding capacity of 5000 m³. The D'Arcy St. booster station supplies water to Zone 2. The Ewart St. booster station, located at the boundary of the two zones, supplies water to the Strathy tower, with a holding capacity of 3734 m³. D'Arcy St. tower, Strathy tower and the Ewart booster station are all equipped with sodium hypochlorite and rechlorination equipment to maintain proper chlorine residuals. Water from the Cobourg DWS is conveyed to Hamilton Township, as an extension of the Cobourg DWS, agreed upon in writing.

3. 2025 COMPLIANCE

3.1 MECP INSPECTION

The MECP began an announced focused inspection of the Cobourg DWS on May 27, 2025. A final inspection rating of 100% was achieved. There were no non-compliances with regulatory requirements or best management practice recommendations identified.


3.2 LICENSE & PERMIT COMPLIANCE

The Cobourg DWS maintained compliance with all applicable legislation, and all terms and conditions of the Municipal Drinking Water License (137-101, Issue 4, June 8, 2021), Drinking Water Works Permit (137-201) and Permit to Take Water (November 10, 2022) in 2025.

The Cobourg DWS Permit to Take Water (Permit No. 3404-CKXRLW) allows the taking of 31,822 m³ of water from Lake Ontario per day at a maximum rate of 31,177L/min. The average flow rate from Lake Ontario was 6,087 L/min, below the maximum rate.

The total quantity of water taken and discharged from the WTP is illustrated in Figure 1 and shown in Table 1 and Table 2. In 2025 there were no incidents related to surpassing the maximum volume of water permitted to take. In September 2025, the WTP operated at 36.8 % of its maximum rated treatment capacity, as shown in Figure 2. The labels presented in Figure 2 are representative of the maximum flow observed for the respective month (m³).

Figure 1 - Flow Quantities for the Cobourg Drinking Water System



	January	February	March	April	May	June	July	August	September	October	November	December
Water Taken (m3)	247,755	227,851	241,461	227,793	263,633	297,790	324,820	315,580	282,998	262,116	248,093	261,174
WTP Discharge (m3)	222,197	207,792	218,552	208,733	249,057	284,856	311,043	303,435	272,124	249,681	232,469	240,143
Daily Average Discharge (m3)	7,168	7,421	7,050	6,958	8,034	9,495	10,034	9,788	9,071	8,054	7,749	8,425
Maximum Daily Discharge (m3)	8,240	10,304	7,959	8,161	10,182	11,413	11,712	11,811	13,382	9,342	8,352	8,868

Water Taken (m3)
 WTP Discharge (m3)
 Daily Average Discharge (m3)
 Maximum Daily Discharge (m3)




Table 1 - Cobourg WTP Influent Flows

	Influent Flows (m3)			
	Monthly Total	Daily Average	Minimum	Maximum
January	247,755	7,992	6,785	8,862
February	227,851	8,138	7,190	11,423
March	241,461	7,789	6,833	8,742
April	227,793	7,593	6,714	8,564
May	263,633	8,504	6,799	10,667
June	297,790	9,926	8,232	11,691
July	324,820	10,478	8,464	12,452
August	315,580	10,180	8,195	12,086
September	282,998	9,433	6,372	13,242
October	262,116	8,455	7,291	9,442
November	248,093	8,270	7,575	8,791
December	261,174	8,425	6,773	9,469
Total	3,201,065			
Average	266,755	8,765		
Maximum				13,241

Table 2 - Treated Water Discharge Flows

	Treated Discharge (m3)			
	Monthly Total	Daily Average	Maximum	% of Max Capacity
January	222,197	7,168	8,240	22.7%
February	207,792	7,421	10,304	28.3%
March	218,552	7,050	7,959	21.9%
April	208,733	6,958	8,161	22.4%
May	249,057	8,034	10,182	28.0%
June	284,856	9,495	11,413	31.4%
July	311,043	10,034	11,712	32.2%
August	303,435	9,788	11,811	32.5%
September	272,124	9,071	13,382	36.8%
October	249,681	8,054	9,342	25.7%
November	232,469	7,749	8,352	23.0%
December	240,143	7,747	8,868	24.4%
Total	3,000,081			
Average	250,708	8,243		
Maximum			13,382	36.8%

3.3 ADVERSE WATER QUALITY INCIDENT(S)

There was one incident of adverse water quality in 2025. On October 14, 2025 there was a de-pressurization of a watermain during tie-in of a new section of main in the Pebblestone area of Cobourg. There was a precautionary boil water advisory issued by the Health Department. All samples were negative for bacteria and the boil water advisory was lifted on October 16, 2025.

4. CONTINUAL IMPROVEMENT

LUSI's commitment to continual improvement requires investigating and investing in, where appropriate, methods and technologies to improve:

- The quality of processes used to ensure production of ample clean water, and
- The quality and effectiveness of the distribution system.

During the 2025 reporting year, LUSI demonstrated this commitment by completing all the activities listed in Table 3. Table 3 also satisfies O. Reg 170/03, the requirement to describe major expenses occurred during the reporting period.

Table 3 – 2025 Major Expenses Incurred at the Cobourg WTP, Distribution System and Misc. Activities		
<i>Cobourg Water Treatment Plant</i>	Chlorine Sample Pump	\$6,125
	Peristaltic Pump CCC	\$8,973
	Water Plant Condition Assessment	\$5,650
	Filter Effluent Channel Valve	\$61,840
	Raw Water Inspection	\$10,000
<i>Cobourg Distribution System</i>	Zone 1 Elevated Tank and Booster Pumping Station	\$6,521,709
	Tower and Booster Pumping Station Project Management	\$653,263
	Linear Infrastructure Zone 1/Zone 2	\$1,900,100
	Linear Infrastructure Zone 1/Zone 2 Infrastructure - PM	\$101,096
	Replace SCADA Pack 32 PLCs – Strathy and Ewart	\$43,511
	ICI Meter Audits	\$35,025
	Watermain Condition Assessment	\$15,354
	Hydrant Coating, Painting and Flow Testing	\$34,529
	Water Rates and Financial Plan	\$10,735
	Watermain Design	\$18,723
	King St. Culvert	\$43,540
	Alexandria Dr. Watermain Replacement	\$283,486
Water Meter Replacement	\$411,547	
<i>Miscellaneous</i>	EA – Zone 3 Cobourg East Community Development	\$10,858
	Tools	\$16,353
	Master Plan Update	\$55,402
	Total	\$10,247,819

5. SAMPLING AND ANALYSIS

The Cobourg DWS exhibited compliance with all sampling and testing as required by *Ontario Regulation 170/03* in the 2020 calendar year. Table 4 illustrates all microbiological testing done under Schedule 10 of *Ontario Regulation 170/03*. There were no instances of adverse water quality as a result of a parameter exceeding its respective maximum acceptable concentration.

	E. Coli, (cfu/100mL)		Total Coliform, (cfu/100mL)		HPC, (cfu/1mL)	
	# of Samples	Range of Results (min # - max #)	# of Samples	Range of Results (min # - max #)	# of Samples	Range of Results (min # - max #)
Raw	52	0 - 0	52	0 - 101	-	N/A
Treated	52	0 - 0	52	0 - 0	52	0 - 4
Distribution	421	0 - 0	421	0 - 0	264	0 - 14

Note: Table 2 contains microbiological sampling taken within the Hamilton Township Stand-alone Distribution System.

Operational testing done under Schedule 7 of Ontario Regulation 170/03 during the 2025 reporting period are tabulated in Table 5.

	Number of Grab Samples	Range of Results (min # - max #)
Filter 1 Turbidity (NTU)	8760 (continuous monitoring)	0.013 – 0.090
Filter 2 Turbidity (NTU)	8760 (continuous monitoring)	0.018 – 0.100
Contact Chamber Effluent Free Chlorine Residual (mg/L)	8760 (continuous monitoring)	1.32 – 1.96

The Cobourg DWS Municipal Drinking Water License (MDWL) requires monthly composite samples of backwash wastewater at the point of discharge to Lake Ontario. Table 6 summarizes the results of the sampling program.

Date of MDWL	Parameter	# of Samples	Maximum Annual Average Concentration (mg/L)	Annual Average Concentration (mg/L)
June 8, 2021	Total Suspended Solids	12	25	2.0
	Total Chlorine Residual	12	0.02	0.016

In addition to the microbiological sampling and testing requirements, sampling and testing is required for chemical, inorganic and organic parameters. Table 7 illustrates Schedule 13, Schedule 23 and Schedule 24 sample analysis results, with no exceedances during the reporting period. If there were multiple samples taken during the reporting period, the most recent sample result is provided. A parameter below the method detection limit indicated by (<), cannot be detected as the concentration is lower than minimum concentration that can be measured and reported with 99% certainty.

PARAMETER	SAMPLE RESULT (µg/L)	SAMPLE DATE
Alachlor	0.02<MDL	6-Jan-2025
Atrazine + N-dealkylated metabolites	0.03	
Azinphos-methyl	0.05<MDL	
Benzene	0.32<MDL	
Benzo(a)pyrene	0.004<MDL	
Bromoxynil	0.33<MDL	
Carbaryl	0.05<MDL	
Carbofuran	0.01<MDL	
Carbon tetrachloride	0.17<MDL	
Chlorpyrifos	0.02<MDL	
Diazinon	0.02<MDL	
Dicamba	0.2<MDL	
1,2-Dichlorobenzene	0.41<MDL	
1,4-Dichlorobenzene	0.36<MDL	
1,2-Dichloroethane	0.35<MDL	
1,1-Dichloroethylene (vinylidene chloride)	0.33<MDL	
Dichloromethane	0.35<MDL	
2,4-dichlorophenol	0.15<MDL	
2,4-dichlorophenoxyacetic acid (2,4-D)	0.19<MDL	
Diclofop-methyl	0.4<MDL	
Dimethoate	0.06<MDL	
Diquat	1<MDL	
Diuron	0.03<MDL	
Glyphosate	1<MDL	
Malathion	0.02<MDL	
MCPA	0.00012<MDL	
Metolachlor	0.01<MDL	
Metribuzin	0.02<MDL	
Monochlorobenzene	0.3<MDL	
Paraquat	1<MDL	
Pentachlorophenol	0.15<MDL	
Phorate	0.01<MDL	
Picloram	1<MDL	
Polychlorinated Biphenyls (PCBs) Total	0.04<MDL	
Prometryne	0.03<MDL	

PARAMETER	SAMPLE RESULT (µg/L)	SAMPLE DATE
Simazine	0.01<MDL	
Terbufos	0.01<MDL	
Tetrachloroethylene (perchloroethylene)	0.35<MDL	
2,3,4,6-tetrachlorophenol	0.2<MDL	
Triallate	0.01<MDL	
Trichloroethylene	0.44<MDL	
2,4,6-trichlorophenol	0.25<MDL	
Trifluralin	0.02<MDL	
Vinyl Chloride	0.17<MDL	
Antimony	0.6 <MDL	
Arsenic	0.2 <MDL	
Barium	19.6	
Boron	21	
Cadmium	0.005	
Chromium	0.20	
Mercury	0.01 <MDL	
Selenium	0.12	
Uranium	0.048	
THM: Annual Average	30.8	14-Oct-25
HAA: Annual Average	4.5	
Nitrite	< 0.003 MDL	
Nitrate	0.329	
Fluoride	0.08	14-Apr-25
Sodium	14.5	

Summary of lead testing under Schedule 15.1 during this reporting period

Location Type	Number of Samples	Range of Lead Results (min#) – (max #) ug/L	Standard (MAC) ug/L	Number of Exceedances
Plumbing	Not required, plumbing exemption and only pH and Alkalinity required in distribution samples			
Distribution	4 (period 1)	Lead (Not required), pH (6.81-6.91), Alkalinity (81-92 mg/L)		
	4 (period 2)	Lead (Not required), pH (7.50-7.70), Alkalinity (81-83 mg/L)		